

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/01
 Name & Address of the Project: M/s Maharishi Markandeshwar University
 Mullana University Road, Mullana
 Ambala, Haryana-133207

Report No.: VEL/W/2007/21/001
 Format No.: 7.8 F-01
 Party Reference No.: NIL
 Reporting Date: 27/07/2020
 Period of Analysis: 21/07/2020 to 27/07/2020
 Receipt Date: 21/07/2020
 Sampling Date: 20/07/2020
 Sampling Quantity: 2.0 Ltr.
 Sampling Type: --

Sample Description: Water Sample
 Sample Location: Dialysis Water for RO
 Sample Collected by: Vardan Enviro Lab Representative
 Preservation: Refrigerated
 Parameter Required: As per work order
 Sampling and Analysis Protocol: IS-10500. APHA

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H' B Electrometric Method	6.88	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	1.41	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	*BDL(**DL 1.0 mg/l)	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl' B, Argentometric Method	*BDL(**DL 1.0 mg/l)	mg/l	250	1000
10.	*Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	*BDL(**DL 0.5 mg/l)	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	5.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	*BDL(**DL 0.1 mg/l)	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	*BDL(**DL 0.2 mg/l)	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34) Chromotropic Method	*BDL(**DL 0.02 mg/l)	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B 1,10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEENU KAUSHIK
 SR. ANALYST
 (Checked By)

ARJUN RAWAT
 (Checked By)

(Approved By)

NOTE: a) The results listed refer only to the tested samples & applicable parameters
 b) Total liabilities of our firm will be restricted to the invoice amount only
 c) The sample will be destroyed after retention time unless otherwise specified
 d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenviromet.com | bd@vardanenviromet.com

Vardan EnviroLab

Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 14001 | ISO 45001

Test Report

Report No: VEL/W/2007/21/001

Sample No.: VEL/MMU/W/01

S.No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable) Limit	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21.	Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01mg/l)	mg/l	0.5	No Relaxation
22.	Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23.	Zinc as Zn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24.	Copper as Cu	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25.	Manganese as Mn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26.	Cadmium as Cd	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.003	No Relaxation
27.	Lead as Pb	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28.	Selenium as Se	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
29.	Arsenic as As	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
30.	Mercury as Hg	APHA, 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope

MEENU KAUSHIK

Sr. Analyst

ARJUN RAWAT

(Checked By)

(Approved By)

The results listed refer only to the tested samples & applicable parameters
 Total liabilities of our lab will be restricted to the invoice amount only
 The sample will be destroyed after retention time unless otherwise specified
 This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/02
Name & Address of the Project: M/s Maharishi Markendeshwar University
Mullana University Road, Mullana
Ambala, Haryana-133207

Report No.: VEL/W/2007/21/002
Format No.: 7.8 F-01
Party Reference No.: NIL
Reporting Date: 27/07/2020
Period of Analysis: 21/07/2020 to 27/07/2020
Receipt Date: 21/07/2020
Sampling Date: 20/07/2020
Sampling Quantity: 2.0 Ltr.
Sampling Type: --

Sample Description: Water Sample
Sample Location: RO Water
Sample Collected by: Vardan Enviro Lab Representative
Preservation: Refrigerated
Parameter Required: As per work order
Sampling and Analysis Protocol: IS-10500, APHA

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA, 4500-II B Electrometric Method	7.81	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA, 2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	50.00	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	10.19	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	41.82	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl B, Argentometric Method	9.62	mg/l	250	1000
10.	Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL (**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	5.97	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	88.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	1.02	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	0.12	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	0.53	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34), Chromotropic Method	0.10	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B I, 10 Phenanthroline Method	*BDL (**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL (**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL (**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEEND KAUSHIK
SR. ANALYST

ARJUN DAVAT

Approved By: [Signature]

1. The results listed refer only to the tested samples & applicable parameters
2. Total liabilities of our lab will be restricted to the invoice amount only
3. The sample will be destroyed after retention time unless otherwise specified
4. The report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com

Vardan EnviroLab

Office: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Office: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 01 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/02
 Name & Address of the Project: M/s Maharishi Markendeshwar University
 Mullana University Road, Mullana
 Ambala, Haryana-133207

Report No.: VEL/W/2007/21/002
 Format No.: 7.8 F-01
 Party Reference No.: NIL
 Reporting Date: 27/07/2020
 Period of Analysis: 21/07/2020 to 27/07/2020
 Receipt Date: 21/07/2020
 Sampling Date: 20/07/2020
 Sampling Quantity: 2.0 Ltr.
 Sampling Type: --

Sample Description: Water Sample
 Sample Location: RO Water
 Sample Collected by: Vardan Enviro Lab Representative
 Preservation: Refrigerated
 Parameter Required: As per work order
 Sampling and Analysis Protocol: IS-10500, APHA

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H ⁺ B Electrometric Method	7.81	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	50.00	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	10.19	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	41.82	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl ⁻ B, Argentometric Method	9.62	mg/l	250	1000
10.	Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	5.97	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	88.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	1.02	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	0.12	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	0.53	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34), Chromotropic Method	0.10	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B 1,10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEEND KAUSHIK
 (Analyst)
 SRIPANDEY

ARJUN RAJAT

(Approved By)

The results listed refer only to the tested samples & applicable parameters
 Total liabilities of our lab will be restricted to the invoice amount only
 The sample will be destroyed after retention time unless otherwise specified
 This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

4242766 | lab@vardanenviro.net.com | bd@vardanenviro.net.com

Vardan EnviroLab

Factory: Plot No 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Lab Off: Plot No 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
ISO 9001 | ISO 14001 | ISO 45001

Test Report

FORM 39 (SEE RULE 150 E (F) UNDER THE DRUGS & COSMETICS ACT 1940 & RULES THEREUNDER)

Sample Name : Dialysis Water	Mfg Lic No. : NA
Name & Address of the Projects : Maaaharishi Markandeshwar University Mullana University Road, Mullana Ambala Haryana -133207	Reports No: VEL/PH/2007/21/003 Date of Receipt : 21.07.2020
B/No. :NA	Date of Report : 27.07.2020
D/M: NA	Ref. No. : NA
D/E:NA	Batch Size:NA Sample Qty:NA

TEST RESULTS

Test Parameters	Results	Limit	Tested Method
<u>Endotoxins</u>	<u>< 0.25 EU/ml</u>	<u>Max. 0.25 EU/ml</u>	<u>IP 2018</u>

REPORT :In the opinion of the undersigned the sample referred to above is of standard quality as defined in the Act and rules made there under for the reason given below in above respects as per IP.

Tested by

NAGENDRA KUMAR
Technical Manager
Checked by

Person-In-charge

5of1

- NOTE: a) The results listed refer only to the tested samples & applicable parameters
b) Total liabilities of our lab will be restricted to the invoice amount only
c) The sample will be destroyed after retention time unless otherwise specified
d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in



Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report


Sample Number: VEL/MMU/W/01
Name & Address of the Project: M/S Maharishi Markendeshwar University
 Mullana University Road, Mullana
 Ambala, Haryana-133207
Sample Description: Water Sample
Sample Location: Dialysis Water for RO
Sample Collected by: Vardan Enviro Lab Representative
Preservation: Refrigerated
Parameter Required: As per work order
Sampling and Analysis Protocol: IS-10500, APHA

Report No.: VEL/W/2006/23/001
Format No.: 7.8 F-01
Party Reference No.: NIL
Reporting Date: 29/06/2020
Period of Analysis: 23/06/2020 to 29/06/2020
Receipt Date: 23/06/2020
Sampling Date: 22/06/2020
Sampling Quantity: 2.0 Ltr.
Sampling Type: --

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 ^o C)	APHA ,4500-H ⁺ B Electrometric Method	6.78	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	1.26	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	*BDL (**DL 0.5 mg/l)	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	*BDL (**DL 1.0 mg/l)	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl ⁻ B, Argentometric Method	*BDL (**DL 1.0 mg/l)	mg/l	250	1000
10.	*Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL (**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	*BDL (**DL 0.5 mg/l)	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	3.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	*BDL (**DL 0.5 mg/l)	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	*BDL (**DL 0.1 mg/l)	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	*BDL (**DL 0.2 mg/l)	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34), Chromotropic Method	*BDL (**DL 0.02 mg/l)	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B 1,10 Phenanthroline Method	*BDL (**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL (**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL (**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEENI KAUSHIK
ANALYST

ARJUN RAWAT
Checked By



NOTE: a) The results listed refer only to the tested samples & applicable parameters
 b) Total liabilities of our lab will be restricted to the invoice amount only
 c) The sample will be destroyed after retention time unless otherwise specified
 d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenviro.net | bd@vardanenviro.net

Vardan EnviroLab

Factory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample No.: VEL/MMU/AV/01					Report No: VEL/W/2006/23/001	
S. No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21.	Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01mg/l)	mg/l	0.5	No Relaxation
22.	Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23.	Zinc as Zn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24.	Copper as Cu	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25.	Manganese as Mn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26.	Cadmium as Cd	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.003	No Relaxation
27.	Lead as Pb	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28.	Selenium as Se	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
29.	Arsenic as As	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
30.	Mercury as Hg	APHA, 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope.

MEENU KAUSHAL
 Sr. ANALYST

ARJUN RAWAT
 Checked By

(Approved By)

- a) The results listed refer only to the tested samples & applicable parameters
- b) Total liabilities of our lab will be restricted to the invoice amount only
- c) The sample will be destroyed after retention time unless otherwise specified
- d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/02
 Name & Address of the Project: M/s Maharishi Markendeshwar University
 Mullana University Road, Mullana
 Ambala, Haryana-133207


Sample Description: Water Sample
 Sample Location: RO Water
 Sample Collected by: Vardan Enviro Lab Representative
 Preservation: Refrigerated
 Parameter Required: As per work order
 Sampling and Analysis Protocol: IS-10500, APHA

Report No.: VEL/W/2006/23/002
 Format No.: 7.8 F-01
 Party Reference No.: NIL
 Reporting Date: 29/06/2020
 Period of Analysis: 23/06/2020 to 29/06/2020
 Receipt Date: 23/06/2020
 Sampling Date: 22/06/2020
 Sampling Quantity: 2.0 Ltr.
 Sampling Type: --

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H ⁺ B Electrometric Method	7.70	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA , 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA , 2340 C, EDTA Titrimetric Method	57.00	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	14.87	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA , 2320 B, Titrimetric Method	51.62	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl ⁻ B, Argentometric Method	11.29	mg/l	250	1000
10.	Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA , 4500 CN- D	4.83	mg/l	30	100
12.	Total Dissolved Solids	APHA , 3500 Mg B, Calculation Method	95.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA , 2540 C, Gravimetric Method	1.15	mg/l	200	400
14.	Fluoride as F	APHA , 4500 E, Turbidimetric Method	0.17	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA , 4500-F- D, SPADNS Method	0.62	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34) ,Chromotropic Method	0.13	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA , 3500-Fe B 1,10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA , 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEET KUSHIK
 Sr. ANALYST

ABHIRAMAT

(Approved By) 

NOTE: a) The results listed refer only to the tested samples & applicable parameters
 b) Total liabilities of our lab will be restricted to the invoice amount only
 c) The sample will be destroyed after retention time unless otherwise specified
 d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | hd@vardanenvironet.com

Vardan EnviroLab

Office: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Office: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 14001 | ISO 45001

Test Report

Sample No.: VEL/MNIU/W/02

Report No: VEL/W/2006/23/002

S.No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable) Limit	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21.	Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01 mg/l)	mg/l	0.5	No Relaxation
22.	Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23.	Zinc as Zn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24.	Copper as Cu	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25.	Manganese as Mn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26.	Cadmium as Cd	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.003	No Relaxation
27.	Lead as Pb	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28.	Selenium as Se	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
29.	Arsenic as As	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
30.	Mercury as Hg	APHA, 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	<2	MPN/100ml	Shall not be detectable in any 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope.

MEENU KAUSHIK
 SR. ANALYST

(Tested By)

ARJUN RAWAT

(Checked By)

(Approved By)

- a) The results listed refer only to the tested samples & applicable parameters
- b) Total liabilities of our lab will be restricted to the invoice amount only
- c) The sample will be destroyed after retention time unless otherwise specified
- d) This report is not to be reproduced without the permission of the lab.

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jalpur - 302035 (Rajasthan)
ISO 9001 | ISO 14001 | ISO 45001

Test Report

FORM 39 [(SEE RULE 150 E (F) UNDER THE DRUGS & COSMETICS ACT 1940 & RULES THEREUNDER)

Sample Name : Dialysis Water	Mfg Lic No. : NS
Name & Address of the Projects : Maaaaharishi Markandeshwar University Mullana University Road, Mullana Ambala Haryana -133207	Reports No: VEL/PH/2006/23/003 Date of Receipt : 23.06.2020
B/No. :NA	Date of Report : 29.06.2020
D/M: NA	Ref. No. : NS
D/E:NA	Batch Size:NS Sample Qty:NS

TEST RESULTS

Test Parameters	Results	Limit	Tested Method
Endotoxins	< 0.25 EU/ml	Max. 0.25 EU/ml	IP 2018

REPORT :In the opinion of the undersigned the sample referred to above is of standard quality as defined in the Act and rules made there under for the reason given below in above respects as per IP .

Tested by

NAGENDRA KUMAR
Technical Manager
Checked by



4of1

NOTE: a)The results listed refer only to the tested samples & applicable parameters
b) Total liabilities of our lab will be restricted to the invoice amount only
c) The sample will be destroyed after retention time unless otherwise specified
d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MIMU/W/01
 Name & Address of the Project: M/s Maharishi Markendeshwar University
Mullana University Road, Mullana
Ambala, Haryana-133207

Sample Description: Water Sample
 Sample Location: Dialysis Water for RO
 Sample Collected by: Vardan Enviro Lab Representative
 Preservation: Refrigerated
 Parameter Required: As per work order
 Sampling and Analysis Protocol: IS-10500, APHA

Report No.: VEL/W/2005/26/001
 Format No.: 7.8 F-01
 Party Reference No.: NIL
 Reporting Date: 01/06/2020
 Period of Analysis: 26/05/2020 to 01/06/2020
 Receipt Date: 26/05/2020
 Sampling Date: 25/05/2020
 Sampling Quantity: 2.0 Ltr.
 Sampling Type: --

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H* B Electrometric Method	6.80	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	1.25	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	*BDL(**DL 1.0 mg/l)	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl* B, Argentometric Method	*BDL(**DL 1.0 mg/l)	mg/l	250	1000
10.	Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	*BDL(**DL 0.5 mg/l)	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	5.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	*BDL(**DL 0.1 mg/l)	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	*BDL(**DL 0.2 mg/l)	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34), Chromotropic Method	*BDL(**DL 0.02 mg/l)	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B 1, 10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

ME EXL KAUSHIK
 S. K. KAUSHIK

ARJUN RAWAT
 (Checked By)

(Approved By)

- The results listed refer only to the tested samples & applicable parameters
- Total liabilities of our lab will be restricted to the invoice amount only
- The sample will be destroyed after retention time unless otherwise specified
- This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenviro.net | bd@vardanenviro.net.com

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 9001 | ISO 14001 | ISO 45001

Test Report

Sample No.: VEL/MIMU/W/01

Report No: VEL/W/2005/26/00

S. No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable) Limit	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21.	Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01mg/l)	mg/l	0.5	No Relaxation
22.	Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23.	Zinc as Zn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24.	Copper as Cu	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25.	Manganese as Mn	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26.	Cadmium as Cd	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.003	No Relaxation
27.	Lead as Pb	APHA, 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28.	Selenium as Se	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
29.	Arsenic as As	APHA, 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
30.	Mercury as Hg	APHA, 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	Absent	MPN/100ml	Shall not be detectable in an 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in an 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope.

MEENU KAUSHIK
 Sr. ANALYST

ARJUN RAWAT

Checked By

Approved By

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/02
 Name & Address of the Project: M/s Maharishi Markendeshwar University
 Mullana University Road, Mullana
 Ambala, Haryana-133207

Report No.: VEL/W/2005/26/002
 Format No.: 7.8 F-01
 Party Reference No.: NIL
 Reporting Date: 01/06/2020
 Period of Analysis: 26/05/2020 to 01/06/2020
 Receipt Date: 26/05/2020
 Sampling Date: 25/05/2020
 Sampling Quantity: 2.0 Ltr.
 Sampling Type: --

Sample Description: Water Sample
 Sample Location: RO Water
 Sample Collected by: Vardan Enviro Lab Representative
 Preservation: Refrigerated
 Parameter Required: As per work order
 Sampling and Analysis Protocol: IS-10500, APHA

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H* B Electrometric Method	7.79	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA, 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA, 2340 C, EDTA Titrimetric Method	54.00	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	13.61	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA, 2320 B, Titrimetric Method	50.13	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl* B, Argentometric Method	10.88	mg/l	250	1000
10.	*Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA, 4500 CN- D	4.87	mg/l	30	100
12.	Total Dissolved Solids	APHA, 3500 Mg B, Calculation Method	91.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA, 2540 C, Gravimetric Method	1.10	mg/l	200	400
14.	Fluoride as F	APHA, 4500 E, Turbidimetric Method	0.16	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA, 4500-F- D, SPADNS Method	0.55	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34), Chromotropic Method	0.12	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA, 3500-Fe B 1,10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA, 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

MEE...KAUSHIK
 Sr. ANALYST

ARJUN RAWAT
 (Checked By)

(Approved By)

- NOTE: a) The results listed refer only to the tested samples & applicable parameters
 b) Total liabilities of our lab will be restricted to the invoice amount only
 c) The sample will be destroyed after retention time unless otherwise specified
 d) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com

Test Report

Sample No: VEL/MMU/W/02

Report No: VEL/W/2005/26/002

S. No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable) Limit	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21	*Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01mg/l)	mg/l	0.5	No Relaxation
22	*Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23	Zinc as Zn	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24	Copper as Cu	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25	Manganese as Mn	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26	Cadmium as Cd	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.003	No Relaxation
27	Lead as Pb	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28	Selenium as Se	APHA , 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
29	Arsenic as As	APHA , 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
30	Mercury as Hg	APHA , 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	<2	MPN/100ml	Shall not be detectable in any 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope.

MEENU KAUSHIK

ANALYST

ARJUN RAWAT

(Checked By)

(Approved By)

a. All the results listed refer only to the tested samples & applicable parameters
 b. Total liabilities of our lab will be restricted to the invoice amount only
 c. The sample will be destroyed after retention time unless otherwise specified
 d. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenviromet.com | bd@vardanenviromet.com

Vardan EnviroLab

Laboratory: Plot No 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Branch Off: Plot No 24 & 25, Narayan Vihar, Block B, Jaipur - 302035 (Rajasthan)
ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number: VEL/MMU/W/01
Name & Address of the Project: M/s Maharishi Markendeshwar University
Mullana University Road, Mullana
Ambala, Haryana-133207
Sample Description: Water Sample
Sample Location: Dialysis Water for RO
Sample Collected by: Vardan Enviro Lab Representative
Preservation: Refrigerated
Parameter Required: As per work order
Sampling and Analysis Protocol: IS-10500, APHA

Report No.: VEL/W/2001/14/001
Format No.: 7.8 F-01
Party Reference No.: NIL
Reporting Date: 20/01/2020
Period of Analysis: 14/10/2019 to 20/01/2020
Receipt Date: 14/01/2020
Sampling Date: 13/01/2020
Sampling Quantity: 2.0 Ltr.
Sampling Type: --

S. No.	Parameter	Test-Method	Result	Unit	Limits of IS:10500 -2012	
					Requirement (Acceptable Limit)	Permissible limit in the Absence of Alternate Source
1.	pH (at 25 °C)	APHA ,4500-H ⁺ B Electrometric Method	6.72	--	6.5 to 8.5	No Relaxation
2.	Colour	APHA ,2120 B, Visual Comparison Method	*BDL (**DL 5Hazen)	Hazen	5	15
3.	Turbidity	APHA, 2130 B, Nephelometric Method	*BDL (**DL 0.1 NTU)	NTU	1	5
4.	Odour	APHA, 2150 B, Threshold Odour Method	Agreeable	--	Agreeable	Agreeable
5.	Taste	APHA , 2160 B, Threshold Test Method	Agreeable	--	Agreeable	Agreeable
6.	Total Hardness as CaCO ₃	APHA , 2340 C, EDTA Titrimetric Method	1.20	mg/l	200	600
7.	Calcium as Ca	APHA, 3500 Ca B, EDTA Titrimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	75	200
8.	Alkalinity as CaCO ₃	APHA , 2320 B, Titrimetric Method	*BDL(**DL 1.0 mg/l)	mg/l	200	600
9.	Chloride as Cl	APHA, 4500-Cl ⁻ B, Argentometric Method	*BDL(**DL 1.0 mg/l)	mg/l	250	1000
10.	Cyanide as CN	APHA, 3500 Cl B Iodometric Method	*BDL(**DL 0.02 mg/l)	mg/l	0.05	No Relaxation
11.	Magnesium as Mg	APHA , 4500 CN- D	*BDL(**DL 0.5 mg/l)	mg/l	30	100
12.	Total Dissolved Solids	APHA , 3500 Mg B, Calculation Method	4.00	mg/l	500	2000
13.	Sulphate as SO ₄	APHA , 2540 C, Gravimetric Method	*BDL(**DL 0.5 mg/l)	mg/l	200	400
14.	Fluoride as F	APHA , 4500 E, Turbidimetric Method	*BDL(**DL 0.1 mg/l)	mg/l	1.0	1.5
15.	Nitrate as NO ₃	APHA , 4500-F- D, SPADNS Method	*BDL(**DL 0.2 mg/l)	mg/l	45	No Relaxation
16.	Iron as Fe	IS 3025 (P-34) ,Chromotropic Method	*BDL(**DL 0.02 mg/l)	mg/l	0.3	No relaxation
17.	Aluminium as Al	APHA , 3500-Fe B 1,10 Phenanthroline Method	*BDL(**DL 0.03 mg/l)	mg/l	0.03	0.2
18.	Boron	APHA , 3111 D, Direct Nitrous Oxide-Acetylene Flame Method	*BDL(**DL 0.1 mg/l)	mg/l	0.5	1
19.	Total Chromium as Cr	APHA, 4500B C, Carmine Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	No Relaxation

HEENU KAUSHIK
SR (Checked By)

ARJUN RAWAT
(Checked By)

(Approved By)

The results listed refer only to the tested samples & applicable parameters
Total liabilities of our lab will be restricted to the invoice amount only
The sample will be destroyed after retention time unless otherwise specified
This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com

Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
 Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
 ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample No.: VEL/MIMU/W/01			Report No: VEL/W/2001/14/001			
S. No	Parameter	Test-Method	Result	Unit	Limits of IS:10500-2012	
					Requirement (Acceptable) Limit	Permissible limit in the Absence of Alternate Source
20.	Phenolic Compounds	APHA, 5530 C Chloroform Extraction Method	*BDL(**DL 0.001 mg/l)	mg/l	0.001	0.002
21.	*Mineral Oil	Clause 6 of IS:3025(Part 39)	*BDL(**DL 0.01mg/l)	mg/l	0.5	No Relaxation
22.	*Anionic Detergents as MBAS	APHA, 5540 C MBAS Method	*BDL(**DL 0.02 mg/l)	mg/l	0.2	1.0
23.	Zinc as Zn	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	5	15
24.	Copper as Cu	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.03 mg/l)	mg/l	0.05	1.5
25.	Manganese as Mn	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL(**DL 0.06 mg/l)	mg/l	0.1	0.3
26.	Cadmium as Cd	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.005	No Relaxation
27.	Lead as Pb	APHA , 3111 B, Direct Air, Acetylene Flame Method	*BDL	mg/l	0.01	No Relaxation
28.	Selenium as Se	APHA , 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	No Relaxation
29.	Arsenic as As	APHA , 3114 B, Manual Hydride Generation	*BDL(**DL 0.01 mg/l)	mg/l	0.01	0.05
30.	Mercury as Hg	APHA , 3112 B, Cold Vapor AAS Method	*BDL (**DL 0.001 mg/l)	mg/l	0.001	No Relaxation
31.	Total Coliform	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	
32.	E. Coli	IS 1622	Absent	MPN/100ml	Shall not be detectable in any 100 ml sample	

Note: - *BDL-Below Detection Limit, **DL- Detection Limit
 *These parameter are not covered in our NABL scope

MEENU KAUSHIK
 ANALYST

ARJUN RAWAT
 (Checked By)

(Approved By)

Vardan EnviroLab

Factory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
Branch Off: Plot No. 24 & 25, Narayan Vihar, Block-B, Jaipur - 302035 (Rajasthan)
ISO 9001 | ISO 14001 | ISO 45001

Test Report


FORM 39 [(SEE RULE 150 E (F) UNDER THE DRUGS & COSMETICS ACT 1940 & RULES THEREUNDER)

Sample Name : Dialysis Water	Mfg Lic No. : NA
Name & Address of the Projects : Maaaharishi Markandeshwar University Mullana University Road, Mullana Ambala Haryana -133207	Reports No: VEL/PH/2001/14/003 Date of Receipt : 14.01.2020
B/No. :NA	Date of Report : 20.01.2020
D/M: NA	Ref. No. : NA
D/E:NA	Batch Size:NA Sample Qty:NA

TEST RESULTS

Test Parameters	Results	Limit	Tested Method
Endotoxins	< 0.25 EU/ml	Max. 0.25 EU/ml	IP 2018

REPORT :In the opinion of the undersigned the sample referred to above is of standard quality as defined in the Act and rules made there under for the reason given below in above respects as per IP.


Tested by

NAGENDRA KUMAR
Technical Manager
Checked by



1of1

1) The results listed refer only to the tested samples & applicable parameters
2) Total liabilities of our lab will be restricted to the invoice amount only
3) The sample will be destroyed after retention time unless otherwise specified
4) This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law

www.vardan.co.in

Tel : 0124-4343750, 4343752, 4343753, 4343766 | lab@vardanenvironet.com | bd@vardanenvironet.com